

WSPCert Certificate

No. BAC-0214-01

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5:2014. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed in the annex of this certificate.

The 2 BACnet General Devices (B-GENERAL)

**DESIGO PX BACnet Router
PXG3.M, PXG3.L**

with the software version:

**FW=01.20.54.29;WPC=1.3.26;
SVS-300:SBC=13.20**

of

Siemens Schweiz AG

Gubelstrasse 22, 6301 Zug, Switzerland

has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 14.0 and the Certification Rules of the BACnet Interest Group Europe, see **MBS Test Report No. VG 2016_12536**.

The certificate is valid
until 2017/04/01

2016/08/25

Date of initial certification



Dipl.-Ing. G. Weinmann
Head of Certification Body

Empowered by
 **BACnet**
INTEREST GROUP EUROPE

Annex to Certificate No. BAC-0214-01

The certification of the BACnet Implementations
DESIGO PX BACnet Router PXG3.M, PXG3.L
of **Siemens Schweiz AG**

refers to the BACnet Interoperability Building Blocks (BIBBs) listed below. BIBBs other than listed are not part of the certification.

BACnet Interoperability Building Blocks	
DS-RP-A	Data Sharing – Read Property – A
DS-RP-B	Data Sharing – Read Property – B
DS-RPM-A	Data Sharing – Read Property Multiple – A
DS-RPM-B	Data Sharing – Read Property Multiple – B
DS-WP-B	Data Sharing – Write Property – B
DS-WPM-B	Data Sharing – Write Property Multiple – B
DM-DDB-A	Device Management – Dynamic Device Binding – A
DM-DDB-B	Device Management – Dynamic Device Binding – B
DM-DOB-B	Device Management – Dynamic Object Binding – B
DM-DCC-B	Device Management – Device Communication Control – B
DM-TS-B	Device Management – Time Synchronization – B
DM-UTC-B	Device Management – UTC Time Synchronization – B
DM-RD-B	Device Management – Reinitialize Device – B
DM-BR-B	Device Management – Backup and Restore – B
DM-R-B	Device Management – Restart – B
DM-LM-B	Device Management – List Manipulation– B